

Tulare County Superior Courts  
IT OFFICE PRE-PROPOSAL CONFERENCE  
Questions and Answers

1. Will flooring be included in the scope of this project? NO
2. Will the concrete walls of the new room in the NE corner need drywall? YES
3. What is the requirement for the counter in the new Collections Office?  
42" high by 32" deep (22" in/10" out) for the regular height counter, 30" high by 32" deep (22" in/10" out) for the ADA compliant/Handicap accessible counter. Windows, desk space, and shelving should mirror as closely as possible the current layout, with the exception that the windows will extend to the ceiling.